

## NOTICE OF PUBLIC HEARING

Caledonia Utility District  
333 4 ½ Mile Road  
Racine, WI 53402  
Central Lift Station and Attenuation Basin Facilities Plan

A public hearing will be held at 6:00PM, December 7, 2022 at the Caledonia Village Hall located at 5043 Chester Lane, Racine, WI. This public hearing is being rescheduled from November 2, 2022.

The Caledonia Utility District along with the Village of Caledonia, WI have prepared a facility plan for an attenuation basin in the Village of Caledonia at the Caledonia Utility District office located at 333 4 ½ Mile Road, Racine, WI 53402. The purpose of the facilities plan is to identify components of the existing lift station that are in need of rehabilitation and to recommend designs for flow attenuation and safety site conveyance. Flow attenuation involves on-site storage of wastewater flows in excess of the allowable flow to the Racine Wastewater Utility (RWWU) collection system, and is commensurate with the findings of the current RWWU Facilities Plan. Safety site conveyance involves routing flow above the allowable flow to the RWWU to a surface water outfall once the storage system is full or filling at capacity.

A public hearing regarding the facility plan and resulting recommended design and construction will be held at 6:00PM, December 7, 2022 at the Caledonia Village Hall located at 5043 Chester Lane, Racine, WI. At this public hearing, all interested persons, and/or their agents or attorneys, may appear before the Village of Caledonia to be heard concerning the project and matters contained within the Central Lift Station and Attenuation Basin Facilities Plan. Comments presented during the public hearing will be taken into consideration with the finalization of the facilities plan. A copy of the facility plan will be available at the Village Clerk's office prior to the hearing.

Notification Dates:    November 2, 2022  
                                 November 16, 2022